



Eau Claire Fire & Rescue
News Media Report

Date: 06-18-12 Dispatch Time: 09:15 Incident Number: 12-3553

Location: 1233 International Drive Phillips Plastics

Incident type: Fire Hazardous Materials Mass Casualty
 Auto Casualty Other _____

Alarms: 1st Alarm 2nd Alarm 3rd Alarm Special Call

Engine(s) Responding: 3 Rescue/Medical vehicle(s): 1

Command Vehicle(s): 1 Number of Personnel Responding: 12

Injuries: Civilian(s) 0 Firefighter(s): 0

Transported by Ambulance: Yes (number _____) No Where:

Fatalities: Yes (number _____) No

Evacuation: Yes No Comments: Main building only

Relocation: Yes No Note:

Mutual Aid: Given Received (units) N/A

Business Name: Phillips Plastics

Occupant Information

Name:

Address:

Phone:

Property Owner Information

Name:

Address:

Phone:

Structure Type: Commercial Area of Origin: Roof HVAC motor

Under Investigation: Yes No By Whom:

Probable Cause: electrical malfunction

Damage Estimate: undetermined. (structure & contents)

Narrative – See next page

Eau Claire Fire & Rescue

News Media Report



Narrative:

The ECFD responded to a report of a structure fire in a commercial building. Part of the building had light smoke that was contained mostly to an office area. The cause of the smoke was due to a malfunctioning HVAC unit on the roof. This incident was probably related to the transformer fire at the same address the day before.

Officer: Battalion Chief Bryon Bensen
Eau Claire Fire Department