



Eau Claire Fire & Rescue
News Media Report

Date: 5-10-12 Dispatch Time: 06:31 Incident Number: 12-2729

Location: 1000 Ferry Street Eau Claire WI

Incident type: [X] Fire [] Hazardous Materials [] Mass Casualty
[] Auto Casualty [] Other _____

Alarms: [] 1st Alarm [X] 2nd Alarm [] 3rd Alarm [] Special Call

Engine(s) Responding: 4 Rescue/Medical vehicle(s): 3

Command Vehicle(s): 2 Number of Personnel Responding: 18

Injuries: Civilian(s) 0 Firefighter(s): 0

Transported by Ambulance: [] Yes (number _____) [X] No Where:

Fatalities: [] Yes (number _____) [X] No

Evacuation: [X] Yes [] No Comments:

Relocation: [] Yes [X] No Note:

Mutual Aid: [] Given [] Received (units) [X] N/A

Business Name: Waste Water Treatment Plant

Occupant Information

Name: City Of Eau Claire
Address:

Phone:

Property Owner Information

Name: City of Eau Claire
Address:

Phone:

Structure Type: Industrial Area of Origin: Parking garage/work shop

Under Investigation: [X] Yes [] No By Whom: Inspector Puljas

Probable Cause: electrical malfunction

Damage Estimate: To Be determined (structure & contents)

Narrative - See next page

Eau Claire Fire & Rescue

News Media Report



Narrative:

ECFD responded to a report of a structure fire at 06:31. The first alarm assignment consists of 3 Engines, 1 ambulance, and 1 Command vehicle. Upon arrival the first in Engine Company gave a radio report which indicated a working structure fire. A Second Alarm was called for which included an additional Engine, Ambulance, Heavy Rescue, and Command vehicle.

The fire was contained to the east end of the main building in the parking/workshop area. The building was evacuated. Two 1.75" hose lines were used to knock down the bulk of the fire. Two gasoline powered fans were used to ventilate the building and a secondary search was performed to make sure the building was clear. One vehicle was a total loss and there was moderate damage to the structure. The probable cause of the fire was an electrical failure in a vehicle.

The administrative section of the building that controls the Waste Water system had slight smoke damage but is still fully functional.

Officer: Battalion Chief Bryon Bensen
Eau Claire Fire Department