

Phone: 715-831-0966

Eau Claire Fire Department

Christian Bell, Fire Chief 216 S. Dewey Street Eau Claire, WI 54701

MEDIA RELEASE

12/6/22 DATE:	CONTACT:	Battalion Chief Brian Toonen	
0838hr DISPATCH TIME:	PHONE #:	17158395013	
22-09686 INCIDENT NO.:	# PAGES:	2	
LOCATION: 800 Wisconsin St (Banbury Place)			
INCIDENT TYPE: Fire Water/Ice Hazardous Materials Mass Casualty Other			
ALARMS: 1st Alarm 2nd Alarm Special Call MABAS			
ENGINE/TRUCK(S) RESPONDING: 4 RESCUE/MEDICAL VEHICLE(S) RESPONDING: 1			
COMMAND VEHICLE: 2 PERSONNEL RESPONDING: 17			
INJURIES: Civilian: 0 Firefighter: 0			
TRANSPORTED BY AMBULANCE: Yes (#:) No WHERE TRANSPORTED: N/A			
FATALITIES: Yes (#:) • No			
EVACUATION: Yes No Comments:			
RELOCATION: Yes No Comments:			
MUTUAL AID: Given Received	● NA		
BUSINESS NAME: American Phoenix Occupant: Name:			
Address: 800 Wisconsin St			
Eau Claire WI 54703			

1



Eau Claire Fire Department

Christian Bell, Fire Chief 216 S. Dewey Street Eau Claire, WI 54701

Property Owner:	
Name:	
Address:	
Phone:	
le ductrial	To LOwer to
STRUCTURE TYPE: Industrial	AREA OF ORIGIN: Trash Compactor
UNDER INVESTIGATION: Yes No	BY MILIONAL Face Claims Fire Demonstrates and
UNDER INVESTIGATION: Yes No	BY WHOM: Eau Claire Fire Department
PROBABLE CAUSE: Under Investigation	
The street of th	
DAMAGE ESTIMATE: \$ 3000	
(structure and contents)	

NARRATIVE:

Eau Claire Fire Department responded to a water flow alarm this morning at 800 Wisconsin St, Banbury Place. Upon arrival, Engine Company No. 10 reported a working fire in the business American Phoenix and requested a 1st Alarm assingment. Two Engine Companies, Two Truck Companies, One medic unit, One Inspector, a Heavy Rescue and Two Chiefs responded. Engine Co. 10 reported the fire was confined to a trash compactor and a fast attack brought the fire under control quickly. Crews checked for extension on the upper floors and reported none. ECFD inspector was on location and is leading the investigation.

Fast confinement and containment of the fire can be attributed to the aid of a working sprinkler system. There were no reported injuries and Eau Claire FD was assisted by Eau Claire PD and the Eau Claire Communication Center.

Allyn Bertrang Deputy Chief Prevention-CRR Matt Jaggar
Deputy Chief
Suppression Operations

Jon Schultz Deputy Chief EMS Operations